

Performance Data

Model RNS3 • 24 x 24 (600 x 600) Face Size

Nominal Neck Size	Neck Velocity, FPM	400	500	600	700	800	900	1000	1200	1400	1600
	Velocity Pressure	.010	.016	.023	.031	.040	.051	.063	.090	.122	.160
6" Dia.	Total Pressure	.017	.027	.038	.052	.068	.086	.106	.153	.208	.272
	Airflow, CFM	80	100	120	140	160	180	200	235	275	315
	Throw	1-1-4	1-2-5	1-2-6	1-3-7	2-4-9	2-5-9	3-6-11	3-6-12	4-7-14	6-8-15
	NC	—	—	—	—	16	19	23	29	34	37
8" Dia.	Total Pressure	.019	.029	.042	.057	.075	.095	.117	.169	.230	.300
	Airflow, CFM	140	175	210	245	280	315	350	420	490	560
	Throw	1-1-5	1-2-6	1-3-8	2-4-8	3-5-10	3-6-10	4-6-13	5-8-13	6-8-16	7-10-17
	NC	—	—	—	15	19	22	26	32	37	40
10" Dia.	Total Pressure	.021	.032	.046	.063	.083	.104	.129	.186	.253	.330
	Airflow, CFM	220	270	330	380	435	490	545	655	765	870
	Throw	1-3-6	2-4-8	3-5-9	4-6-12	5-6-12	5-7-14	6-9-15	6-10-15	8-13-17	9-13-18
	NC	—	—	—	17	22	25	29	35	39	43
12" Dia.	Total Pressure	.023	.036	.052	.071	.093	.118	.146	.210	.286	.373
	Airflow, CFM	315	390	470	550	630	705	785	990	1100	1255
	Throw	2-3-7	3-4-9	3-5-10	4-6-13	5-7-13	5-8-15	5-8-16	7-9-18	9-11-18	10-12-19
	NC	—	—	15	20	25	28	31	37	41	44
14" Dia.	Total Pressure	.027	.042	.060	.082	.107	.136	.168	.241	.328	.429
	Airflow, CFM	425	530	635	745	850	955	1060	1270	1490	1695
	Throw	3-4-9	4-5-11	4-7-13	5-7-16	6-9-16	7-11-16	7-11-19	9-13-19	11-16-19	11-16-27
	NC	—	—	19	24	27	31	34	39	43	47
15" Dia.	Total Pressure	.029	.045	.065	.089	.116	.147	.182	.262	.356	.465
	Airflow, CFM	490	615	735	860	985	1110	1230	1470	1720	1970
	Throw	5-7-10	6-8-11	7-9-14	8-10-17	8-13-18	10-15-19	11-16-22	12-18-27	13-20-32	15-22-34
	NC	—	15	21	25	28	32	35	40	44	48

D
CEILING DIFFUSERS

Performance Notes:

1. Throws are given at 150, 100 and 50 fpm terminal velocities under isothermal conditions.
2. If the diffuser is mounted on an exposed duct, multiply throw values by x 0.70.
3. All pressures are in inches w.g.. To obtain static pressure, subtract the velocity pressure from the total pressure.
4. NC (Noise Criteria) values are based upon 10dB room absorption, re 10⁻¹² watts. Dash (-) in space indicates an NC of less than 15.
5. Data derived from tests conducted in accordance with ANSI/ASHRAE Standard 70 – 2006.

6. The addition of quadrant blanks reduces the effective area and for a given air volume, increases the discharge velocity. This will result in an increase in throw, pressure drop and sound level. To determine throw, select the diffuser as if it were supplying a larger volume of air. The table shows the percentage increase required to determine selection of diffuser size and throw. To correct pressure drop and NC, use correction factors as shown for 4-way blow values.

Neck Size Diameter in Inches	Nominal Overall Face Size	Ak Factor
6	24 x 24	0.180
8	24 x 24	0.227
10	24 x 24	0.331
12	24 x 24	0.450
14	24 x 24	0.511
15	24 x 24	0.625

Quadrant Blanks (Blow)	% Increase in Air Volume for Throw Determination	% Increase in Static Pressure Drop	NC Sound Level Increase
1 (3-way)	35	125	8
2 (2-way)	100	450	19